DIN EN 15714-2:2010-02 (E)

Industrial valves - Actuators - Part 2: Electric actuators for industrial valves - Basic requirements

Contents

Page

Foreword 4

1 Scope 5

2 Normative references 5

3 Classification/Designation 5
3.1 General 5
3.2 Type: Part-turn, multi-turn or linear 5
3.3 Actuator duty classification 6
3.3.1 General 6
3.3.2 Class A: On-off 6
3.3.3 Class B: Inching/positioning 6
3.3.4 Class C: Modulating 6
3.3.5 Class D: Continuous modulating 6
3.4 Action on loss of external electric power 6
3.4.1 Standard action 6
3.4.2 Fail safe action 6

4 Design requirements 6
4.1 Endurance 6
4.1.1 General 6
4.1.2 Part turn actuators 7
4.1.3 Multi-turn actuators 7
4.1.4 Linear actuators 8
4.2 Environmental conditions 8
4.2.1 General 8
4.2.2 Ambient temperature and humidity 8
4.2.3 Altitude 8
4.2.4 Enclosure protection 8
4.2.5 Hazardous areas 8
4.2.6 External corrosion protection 9
4.2.7 Vibrations, shock and seismic conditions 9
4.3 Actuator attachment .....
4.3.1 Part-turn actuators .....
4.3.2 Multi-turn actuators 10
4.3.3 Linear actuators 10
4.4 Standard closing direction 11
4.5 Fail safe direction 11
4.6 Electrical connections -- cable entries 12
4.7 Performance 12
4.7.1 Power supply tolerances 12
4.7.2 Actuator duty performances 12
4.7.3 Operating time and speed 14
4.8 Basic requirements 14
4.8.1 Motors 14
4.8.2 Gearing and lubrication 14
4.8.3 Manual operation 15
4.8.4 Travel limitation 15
4.8.5 Torque/Thrust limitation 15
4.8.6 End stop adjustment for part-turn and linear actuators 15

4.8.7 Local position indication 15

10 10 5.1 General 16

5.2 Anti-condensation heater 16
5.3 Local position indication (for multi-turn or linear actuators) 16
5.4 Position transmitter 16
5.5 Actuator running transmitter 16
5.6 Additional position and/or torque signalling 16
5.7 Local control station 16
5.8 Actuator electrical controls 16
5.8.1 General 16
5.8.2 Positioner 17
5.8.3 Controller 17
5.8.4 Speed Control 17
5.8.5 Field Bus system interface 17
5.8.6 Torque transmitter (analogue or digital) 17
5.8.7 Actuator performance data logger 17

6 Conformity assessment 17
6.1 General 17
6.2 Type tests 18
6.3 Control of production process and quality system 18

7 Marking 19

8 Documentation 20

Annex A (normative) Endurance test procedure 21

A.1 General 21
A.2 Test equipment 21
A.3 Test conditions 21
A.4 Test procedure 21
A.5 Acceptance criteria 21

Annex B (informative) Actuator selection guidelines 22

B.1 General 22
B.2 Selection parameters 22
B.2.1 General 22
B.2.2 Valve Questions 22
B.2.3 Actuator Questions 23
B.3 Ancillary Questions 23
B.4 Environmental conditions (as indicated in 4.2) 23
B.5 Actuator selection 23

Bibliography 24

5 Optional equipment 16