DIN EN 14637:2008-01 (E)

Building hardware - Electrically controlled hold-open systems for fire/smoke door assemblies - Requirements, test metho ds, application and maintenance

Contents

Page

Foreword 5

Introduction 6

1 Scope 9

2 Normative references 9

3 Terms, definitions and abbreviated term 11

4 Classification 13
4.1 Coding system 13
4.2 Category of use (first digit) 13
4.3 Durability (second digit) 13
4.4 Door type (third digit) 13
4.5 Suitability for use on fire/smoke door assemblies (fourth digit) 14
4.6 Safety (fifth digit) 14
4.7 Corrosion resistance (sixth digit) 14
4.8 Example of classification 14

5 Requirements and test methods for components of a hold-open system 15
5.1 General 15
5.2 Fire detectors 15
5.2.1 Smoke detectors 15
5.2.2 Heat detectors 15
5.2.3 Resetting the detectors 15
5.3 Power supply units 16
5.3.1 All power supply units 16
5.3.2 For power supply units with stand-by parallel operation 16
5.4 Control units 17
5.4.1 General 17
5.4.2 Control units in stand-alone hold-open systems (single-line systems) 17
5.4.3 Control units in fire detection and fire alarm systems (multi-line systems) 17
5.5 Hold-open devices 18
5.5.1 General 18
5.5.2 Hold-open devices for swing doors 18
5.5.3 Hold-open devices for sliding doors, lifting doors, industrial doors and roller shutters 18
5.5.4 Automatic door operators 19
5.5.5 Low energy/power assisted swing door operators 19
5.5.6 Free-swing door closers 20
5.6 Auxiliary equipment 20
5.6.1 Manual control push-buttons and switches 20
5.6.2 Presence sensors (electro-sensitive protective equipment) 20
5.6.3 Door position sensors 21
5.6.4 Remote indicating devices 21
5.6.5 Manual reset 21

6 Requirements for the hold-open system 21
6.1 Design and performance 21
6.2 Product information 22
6.2.1 General 22

6.2.2 For installation and maintenance 22
6.2.3 For initial hold-open system test 23
6.3 Requirements not covered under Clause 5 23
6.4 Electromagnetic compatibility (EMC) 23
6.5 Additional design requirements for connection of components to fire alarm systems 24
6.6 Electrical safety 24
6.7 Durability 24
6.8 Environmental behaviour 25
6.8.1 Dry heat 25
6.8.2 Cold 25
6.8.3 Damp heat, steady state (operational) 25
6.8.4 Corrosion 25
6.8.5 Vibration 25
6.9 Supply voltage variations 25

7 System tests 25
7.1 General 25
7.2 Test apparatus 26
7.3 Theoretical analysis 27
7.4 Test methods 27
7.4.1 General 27
7.4.2 Design verification 28
7.4.3 Performance tests 28
7.4.4 Check of switching device capabilities of the control unit 30
7.4.5 Short-circuit test 30
7.4.6 Electrical safety tests 30
7.4.7 Electromagnetic compatibility (EMC) tests 30
7.4.8 Environmental tests 31
7.4.9 Corrosion test 32
7.4.10 Vibration test, sinusoidal (operational) 33
7.4.11 Vibration test, sinusoidal (endurance) 33

8 Marking 35
8.1 Components 35
8.2 Hold-open system 35

A.1 General 36
A.2 Restrictions 36
A.3 Detectors 36
A.3.1 Selection of detector type 36
A.3.2 Positioning and number of detectors 37
A.4 Selection of hold-open device 43
A.4.1 General 43
A.4.2 Swing doors 43
A.4.3 Sliding doors 44
A.4.4 Roller shutter and lifting doors 44
A.4.5 Automatic doors 44
A.5 Manual release and manual control 44
A.5.1 General 44
A.5.2 Location of switch/push-button 45
A.6 Interconnecting cables 45
A.7 Guidance on competence and responsibilities for individual installations in individual buildings 45
A.7.1 Planning 45
A.7.2 Installation 45

E.1 Usage of installations 50
E.1.1 General 50
E.1.2 Periodic inspection 50

Annex C (informative) Recommendations for acceptance inspection of the hold-open system 47

Annex B (informative) Recommendations for installation and fixing of the hold-open system 46

Annex D (informative) Acceptance inspection report form 48

Annex E (informative) Recommendations for usage and maintenance of the hold-open system 50

Annex A (informative) Recommendations for planning and design of the hold-open system 36
E.2 F.1 General 52

F.1.1 Introduction 52
F.1.2 Initial type test 52
F.1.3 Characteristics 52
F.1.4 Use of historical data 53
F.1.5 Treatment of calculated values and design 53
F.1.6 Sampling, testing and conformity criteria 53
F.2 Factory production control (FPC) 53
F.2.1 General 53
F.2.2 FPC requirements for all manufacturers 54
F.3 Further testing of sample systems 54
F.3.1 Periodic testing 54
F.3.2 Yearly testing 54
F.3.3 Manufacturer-specific FPC system requirements 54

G.1 Test report 57
G.2 List of approved components 57

H.1 Introduction 58
H.2 Points for analysis 58
H.2.1 General 58
H.2.2 List of characteristics 58

Bibliography 62

Figure 1 -- Basic system components with essential functions 6

Figure 2 -- Typical system with additional functions and components 7

Figure 3 -- Logic diagram for modes of operation of an electrically controlled hold-open system 8

Figure A.1 -- Ceiling types and critical dimensions 38

Figure A.2 -- Installation area in accordance with A.3.2.1 39

Figure A.3 -- Flow chart to determine the requisite number of detectors 40

Figure A.4 -- Typical electrically controlled hold-open system with release of connected hold-open devices triggered directly by the FDAS (see A.3.2.2 a)) 41

Figure A.5 -- Typical electrically controlled hold-open system with release of connected hold-open devices by the control unit of the hold-open system driven by the information coming from the FDAS (see A.3.2.2 b)) 42

Table G.1 -- List of approved components 57

Routine site inspection report form 50

Annex G (informative) Type test report and list of approved components 57

Annex F (informative) Evaluation of conformity 52

Annex H (informative) Example methodology for theoretical analysis 58