DIN EN 13501-4:2016-12 (E)

Fire classification of construction products and building elements - Part 4: Classif ication using data from fire resistance tests on components of smoke control systems

Contents

Page

European foreword 4

Introduction 5

1 Scope 6

2 Normative references 6

3 Terms and definitions 7

4 Fire scenarios 8
4.1 General 8
4.2 The standard temperature/time curve (post flash-over fire) 9
4.3 The slow heating curve (smouldering fire) 9
4.4 Constant temperature attack 9
4.5 Specific thermal actions 10
4.5.1 Smoke control ducts 10
4.5.2 Smoke control dampers 10
4.5.3 Smoke barriers 10
4.5.4 Powered smoke and heat control ventilators 10
4.5.5 Natural smoke and heat exhaust ventilators 10

5 Resistance to fire performance characteristics 11
5.1 General 11
5.2 Performance characteristics 11
5.2.1 E - Integrity 11
5.2.2 I - Insulation 12
5.2.3 S - Smoke leakage 12
5.2.4 D - Stability duration under constant temperature 12
5.2.5 DH - Stability duration under the standard time-temperature curve 12
5.2.6 F - Functionality of powered smoke and heat ventilators 13
5.2.7 B - Functionality of natural smoke and heat ventilators 13

6 Declaration of performance 13
6.1 Classification periods 13
6.2 Designatory letters 13
6.3 Declaration of performance 13
6.4 Declaration of classes in product standards 13
6.5 Number of tests required for classification 13
6.6 Presentation of classification 14

7 Classification procedure for fire resistance 14
7.1 General 14
7.1.1 Procedure 14
7.1.2 General rules for deducing the number of fire resistance tests 15
7.1.3 Field of application 15
7.2 Classification of smoke control ducts 16
7.2.1 General 16
7.2.2 Test methods and field of application rules 16

7.2.3 Tests to be performed 16
7.2.4 Performance criteria 17
7.2.5 Classes 18
7.3 Classification of smoke control dampers 19
7.3.1 General 19
7.3.2 Test method and field of application rules 19
7.3.3 Tests to be performed 19
7.3.4 Performance criteria 20
7.3.5 Classes 22
7.4 Classification of smoke barriers 23
7.4.1 General 23
7.4.2 Test method 23
7.4.3 Tests to be performed 23
7.4.4 Performance criteria 24
7.4.5 Classes 24
7.5 Classification of powered smoke and heat control ventilators 24
7.5.1 Test method 24
7.5.2 Tests to be performed 24
7.5.3 Performance criteria 24
7.5.4 Classes 25
7.6 Classification of natural smoke and heat exhaust ventilators 25
7.6.1 Test method 25
7.6.2 Tests to be performed 25
7.6.3 Performance criteria 25
7.6.4 Classes 25

Annex A (normative) Classification report 26

A.1 General 26
A.2 Content and format 26