DIN 1946-4:2018-09 (E)

Ventilation and air conditioning - Part 4: Ventilation in buildings and rooms of health care

Contents

Page

Foreword 5

1 Scope 6

2 Normative references 6

3 Terms and definitions, and abbreviated terms 8
3.1 Terms and definitions 8
3.2 Abbreviations 11

4 General principles 12
4.1 Participation of a hospital epidemiologist, hygiene engineer and safety engineer 12
4.2 Necessity of ventilation systems 12
4.3 Documenting deviations from this standard 12

5 Room classes and ventilation requirements 12
5.1 General 12
5.2 Classification of rooms used for medical purposes into room classes 13
5.3 Room class I 13
5.3.1 General 13
5.3.2 Room class Ia 14
5.3.3 Room class Ib 15
5.4 Room class II 15
5.5 Ventilation requirements 15

6 Requirements for VAC components 23
6.1 General requirements 23
6.1.1 General 23
6.1.2 Surfaces and materials within the air flow 23
6.1.3 Cleaning management plan 23
6.1.4 Labelling 23
6.2 Outdoor air intake, exhaust air outlets and surrounding area 24
6.3 Air ducts 25
6.3.1 General requirements 25
6.3.2 Outdoor air ducts 26
6.3.3 Supply air ducts 26
6.3.4 Smoke extraction ducts 26
6.3.5 Inspection openings 26
6.4 Dampers 27
6.4.1 General requirements 27
6.4.2 Outdoor air and exhaust air shut-off dampers 27
6.5 Air handling units (AHU) 27
6.5.1 General requirements 27
6.5.2 Location of components 28
6.5.3 Mechanical characteristics of the equipment casing 28
6.5.4 Outdoor air inlet 29
6.5.5 Basins and siphons 29
6.5.6 Dampers 29
6.5.7 Air filters 30
6.5.8 Heat exchangers 32
6.5.9 Heat recovery systems 33

6.5.10 Fans ... 33
6.5.11 Air humidifiers ... 33
6.5.12 Sound attenuators ... 34
6.5.13 Volume flow controllers ... 34
6.5.14 Monitoring equipment ... 34
6.6 HEPA filters ... 34
6.7 Air terminal devices ... 35
6.7.1 General requirements ... 35
6.7.2 Unidirectional (low-turbulence) flow outlet (LTF outlet) ... 35
6.7.3 Overflow openings ... 36
6.8 Space heating systems and cooled ceilings/cooling devices ... 36
6.9 Building automation and control systems (BACS) ... 36
6.10 Repairs, cleaning and disinfection ... 37
6.11 Operation and maintenance ... 37

7 System qualification and acceptance inspection ... 37
7.1 General ... 37
7.2 System qualification ... 38
7.2.1 Installation qualification ... 38
7.2.2 Functional qualification ... 38
7.2.3 Performance qualification ... 40
7.3 Technical acceptance inspection ... 40
7.4 Hygienic acceptance inspection ... 43
7.4.1 Basic requirements ... 43

8 Periodic inspection ... 45
8.1 General requirements ... 45
8.2 Technical inspection ... 45
8.3 Hygienic inspection ... 45

Annex A (informative) Guidance for the project-planning phase ... 47

A.1 Project phases and objectives ... 47
A.2 Analysis ... 48
A.2.1 Determine the as-is situation ... 48
A.2.2 Risk analysis for existing systems ... 48
A.2.3 Establish basic considerations ... 48
A.2.4 Declare general intent and draw up performance specifications ... 48
A.3 Project objectives ... 48
A.3.1 Prerequisites ... 48
A.3.2 Performance specifications ... 49
A.3.3 Conclusion of definition of objectives phase ... 49
A.4 Design ... 49
A.4.1 Prerequisites ... 49
A.4.2 Translation of specifications into design ... 50
A.4.3 Conclusion of design phase ... 50
A.5 Realization ... 50
A.5.1 Prerequisites ... 50
A.5.2 Using the performance specifications ... 51
A.5.3 System qualification ... 51
A.5.4 Documentation ... 51
A.5.5 Conclusion of realization phase ... 51
A.6 Operation ... 52
A.6.1 Prerequisites ... 52
A.6.2 Training of personnel ... 52
A.6.3 Updating system documentation ... 52
A.6.4 Building automation and control systems (BACS) ... 52
A.6.5 Maintenance management ... 52
A.6.6 Disposal of air filters ... 53

Annex B (normative) Preliminary test (flow visualization) ... 54

B.1 Objective 54
B.2 Outflow behaviour 54
B.2.1 LTF outlet and light lead-through 54
B.2.2 Surgical lights and satellites 55
B.3 Shielding of the protected area 55
B.3.1 Testing 55
B.3.2 Evaluation 55

Annex C (normative) Determining the degree of protection 56

C.1 Objective 56
C.2 Procedure 56
C.2.1 General 56
C.2.2 Reference particle load 56
C.2.3 Reference loads, reference load test set-up 57
C.2.4 Effect of protection against load entry from the outside 57
C.2.5 Effect of protection against load entry from the inside 57
C.2.6 Determining the boundaries of the protected area 60
C.2.7 Determining the degree of protection 60
C.2.8 Determining the protective effect 61
C.3 Requirements 61

Annex D (normative) Measuring turbulence intensity 62

D.1 Objective 62
D.2 Procedure 62
D.2.1 General 62
D.2.2 Measuring and marking test positions 63
D.2.3 Procedure for TI measurement 64
D.3 Requirements 65
D.3.1 Protected area 65
D.3.2 LTF outlet, separate (with temporary stabilizer surrounding outlet) 65

Annex E (informative) System test of surgical lights 66

E.1 Objective 66
E.2 Test framework conditions 66
E.3 Manufacturer's specifications 66
E.4 Minimum test conditions 66
E.4.1 General 66
E.4.2 Lights / satellites 66
E.5 Turbulence intensity measurement 67
E.5.1 General 67
E.5.2 Measuring and marking test positions 67
E.6 Requirements 67

Annex F (informative) Microbiological monitoring 68

F.1 Objective 68
F.2 Procedure 68
F.3 Requirements 68
F.4 Results and evaluation 68
F.5 Sedimentation plates (settle plates) 68

Bibliography 70