

DIN EN 17690-1:2026-02 (E)

Components for BAC control loop - Sensors - Part 1: Room temperature sensors

Contents		Page
European foreword		4
Introduction		5
1 Scope		6
2 Normative references		6
3 Terms and definitions		6
4 Symbols, units, subscripts and abbreviations		8
5 Room temperature sensor device		9
6 Requirements		10
6.1 Electrical requirements		10
6.1.1 Electromagnetic compatibility		10
6.1.2 Degree of protection		10
6.2 Declarations by the manufacturer		10
6.2.1 General		10
6.2.2 Protection class		10
6.2.3 Measuring range		10
6.2.4 Sensor (device) accuracy		10
6.2.5 Time constant t_{63}		11
6.2.6 Wall coupling coefficient k_W		11
6.2.7 Self-heating compensation		12
6.2.8 Output signals		12
6.2.9 Power supply		13
6.2.10 Power consumption of the device		13
6.2.11 Electrical connection		13
6.2.12 Dimensions		13
6.2.13 Weight		13
6.2.14 Environmental conditions		13
7 Test set-up		13
7.1 Test equipment		13
7.1.1 Climatic chamber		13
7.1.2 Wall modules		15
7.2 Test installation		19
7.2.1 Mounting of the Device Under Test (DUT)		19
7.2.2 Wiring of the room sensor devices		19
7.2.3 Reference sensor position		19
7.3 Temperature homogeneity		21
7.4 Determination of the mean air velocity		22
7.5 Homogeneity of air velocity		22
8 Test methods		23
8.1 Sensor accuracy		23
8.1.1 General		23
8.1.2 Test conditions sensor accuracy test		23
8.1.3 Impact of temperature variation t_{var}		24
8.1.4 Impact of air velocity variation air_{vel}		24

8.1.5	Impact of power supply of the device psup	25
8.2	Time constant	25
8.2.1	General	25
8.2.2	Test conditions	26
8.3	Wall coupling	27
8.3.1	General	27
8.3.2	Test conditions	28
8.4	Power consumption measurement	29
8.4.1	General	29
8.4.2	Average active power	29
8.4.3	Average apparent power	30
8.4.4	Inrush peak current and periodic peak current measurement	30
9	Marking and documentation	30
9.1	Marking	30
9.2	Documentation	31
Annex A (informative) Measurements		32
A.1	24 V power supply / 0 V to 10 V sensor output	32
A.2	24 V power supply / 4 mA to 20 mA sensor output	33
A.3	24 V power supply (4 mA to 20 mA in the loop), 4 mA to 20 mA sensor output	34
A.4	24 V power supply, sensor output: Bus signal (e.g. KNX)	35
A.5	24 V power supply: bus powered, sensor output: Bus signal (e.g. KNX)	36
A.6	Inrush and periodic peak current measurement	36
A.7	Correction factor air velocity inside the test chamber	37
Bibliography		41