

DIN EN ISO 16784-2:2025-04 (E)

Corrosion of metals and alloys - Corrosion and fouling in industrial cooling water systems - Part 2: Evaluation of the performance of cooling water treatment programmes using a pilot-scale test rig (ISO 16784-2:2024)

Contents		Page
European foreword		3
Foreword		4
Introduction		5
1	Scope	6
2	Normative references	6
3	Terms and definitions	6
4	Principle	8
5	Water for test	8
	5.1 General.....	8
	5.2 Water characteristics.....	8
	5.3 Preparation of synthetic test waters using mother solutions.....	9
6	Apparatus	9
	6.1 Heat exchanger section.....	9
	6.2 Temperature measurement.....	10
	6.3 Circulation-rate monitor.....	10
	6.4 Make-up, evaporation and blow-down measurement.....	10
	6.5 Cooling tower.....	10
	6.6 Heating system.....	10
	6.7 Water treatment equipment simulation device.....	10
	6.8 On-line detection device.....	11
7	Test method	11
	7.1 Procedure.....	11
	7.1.1 Cleaning of the test assembly.....	11
	7.1.2 Test tube preparation and pre-treatment.....	11
	7.1.3 System water content.....	11
	7.1.4 Procedure to fill the cooling water system.....	12
	7.1.5 Heating the test tubes.....	12
	7.1.6 Flow rate.....	12
	7.1.7 Blow-down and half-life.....	13
	7.1.8 Biocide treatment.....	13
	7.1.9 Make-up water for cooling-tower use.....	13
	7.2 Determination of analytical and control parameters.....	14
	7.3 Test data reporting.....	14
	7.4 Test termination.....	14
8	Assessment of results	14
	8.1 Recording of cooling water quality.....	14
	8.2 Treatment of the test tubes.....	14
	8.3 Assessment of results on deposition and fouling.....	14
	8.4 Assessment of results on corrosion.....	15
	8.4.1 Corrosion phenomena and type of corrosion.....	15
	8.4.2 Pitting corrosion.....	15
	8.4.3 Corrosion rate.....	15
9	Test report	16

Annex A (informative) Test data sheet on the performance of cooling water treatment programmes 17

Annex B (informative) Further information on measurement and test methods 20

Bibliography 25