DIN SPEC 91043:2021-09 (E)

Remote monitoring for decentralized drinking water treatment plants; Text in English

Inhalt

Seite

Foreword 4

Introduction 5

1 Scope 6

2 Normative references 6

3 Terms and definitions 6

4 General 7
4.1 Plant description 7
4.1.1 General 7
4.1.2 Flowmeter (in) 7
4.1.3 Lead pump 7
4.1.4 Pre filtration 7
4.1.5 Disinfection 7
4.1.6 High pressure pump 8
4.1.7 Pressure sensor 8
4.1.8 Membrane filter 8
4.1.9 Flowmeter (out) 8
4.1.10 Water quality sensor 8
4.1.11 Variable frequency converter of lead pump 8
4.1.12 Variable frequency converter of high pressure pump 8
4.1.13 Wastewater tank 8
4.1.14 Drinking water tank 8
4.2 Library blocks 8
4.2.1 General 8
4.2.2 Station related locking 8
4.2.3 Authorization levels 9
4.2.4 General faceplate functions for local operation 9
4.3 System architecture 10

5 Maintenance Analysis 10
5.1 General 10
5.2 On-Site maintenance 10
5.3 Parameters to be monitored, their extent and units 11

6 Data Transmission 11

7 IT Security 12
7.1 General 12
7.2 Concept according to IEC 62443 series 12
7.2.1 General 12
7.2.2 Plant Security 12
7.2.3 Network Security 12
7.2.4 System Integrity 13
7.3 Solution Engineering 13
7.3.1 General 13
7.3.2 Project Security Objectives & Business Impact 13
7.3.3 Security Threat & Risk Analysis 13
7.3.4 Security Requirements 13
7.3.5 Secure Architecture & Design 13

7.3.6 Secure Supplier and Component Selection 13
7.3.7 Secure Coding 13
7.3.8 Secure Configuration & Hardening 14
7.3.9 Security Testing 14
7.4 System Configuration/Hardware requirements 14
7.4.1 General 14
7.4.2 Minimum Standard for the internet connection 14
7.4.3 Virtual Private Network (IPsec) 14
7.5 Secure development process/secure lifecycle 15
Bibliography 16

Figures

Figure 1 — Typical plant design 7
Figure 2 — Example for a menu 9
Figure 3 — System architecture 10
Figure 4 — Defense in depth 12
Figure 5 — Solution Engineering 13
Figure 6 — Example of system configuration 14

Tables

Table 1 — Authorization levels 9
Table 2 — Operation and the maintenance analysis of minimum parameters 11