IEC 88528-11:2004-03 (E)

Reciprocating internal combustion engine driven alternating current generating sets_- Part_11: Rotary uninterruptible power systems_- Performance requirements and test methods

CONTENTS

FOREWORD 5

1 Scope 7
2 Normative references 7
3 Terms and definitions 8
3.1 General 8
3.2 Performance of systems and components 9
3.3 Specified values 10
3.4 Input values 11
3.5 Output values 12
4 Symbols and abbreviations 12
5 Selection criteria 12
6 General description 13
6.1 Rotary UPS 13
6.2 Types of rotary UPS 13
6.2.1 Series connected rotary UPS 13
6.2.2 Line interactive rotary UPS 14
6.3 Parallel operation of a rotary UPS installation 15
6.3.1 General 15
6.3.2 Parallel operation 15
6.3.3 Redundant operation 15
6.4 Power system changeover with rotary UPS installations (bypass) 16
6.5 Enclosure protection 16
7 Modes of operation 16
7.1 Power conditioning mode 17
7.2 Independent mode 17
7.3 Bypass mode 18
7.4 Off mode 18
7.5 Transitions 18
7.5.1 Transition 1, starting the system with mains voltage present 18
7.5.2 Transition 2, start-up without mains voltage (black start) 18
7.5.3 Transition 3, disconnect from grid 19
7.5.4 Transition 4, connect to grid 19
7.5.5 Transition 6, transfer 19
7.5.6 Transition 7, 8, retransfer 19
8 Service conditions 19
8.1 Normal service conditions 19
8.2 Operation at extended ambient 19
8.2.1 Ambient service temperature 19
8.2.2 Ambient storage and transportation conditions 19
8.3 Engines 20
8.4 Rotating electrical machines 20
8.5 Control logic 20

9 Electrical service conditions and performance 20
9.1 General – all rotary UPS 20
9.2 Performance 21
10 Manufacturer technical declarations 22
10.1 General 22
10.2 Purchaser specification guidelines 22
10.2.1 Type of rotary UPS, additional features, and system requirements 23
10.2.2 Rotary UPS input 23
10.2.3 Load to be supplied from a rotary UPS 23
10.2.4 Rotary UPS output 24
10.2.5 Battery (where applicable) 24
10.2.6 General application requirements and special service conditions 25
10.2.7 Multi-module system configurations 25
10.2.8 Electromagnetic compatibility 26
11 Testing 27
11.1 Static output voltage and frequency deviations 27
11.2 Dynamic output voltage and frequency deviations 28
11.3 Input current characteristics 28
11.4 Measurement of filter properties 28
11.4.1 From mains to output 28
11.4.2 From output to mains 30
11.5 System performance 30
11.5.1 Efficiency 30
11.5.2 Stored energy times 30
11.5.3 Multi-module rotary UPS performance 30
11.6 Black start test 31
11.7 Environmental tests 31
11.8 Audible noise 31
11.9 Testing 31
12 Maintenance and product marking 33
12.1 Nameplate markings 33
12.2 Label requirements 34
12.3 Name plate marker 34
12.4 Decals – labelling 35
12.4.1 Safety instructions and documentation 35
12.5 Maintenance 35

Annex A (informative) Typical energy storage devices 36
Annex B (normative) Reference non-linear load – Single-phase 40
Annex C (normative) Reference non-linear load – Three-phase 42
Annex D (normative) Input mains failure – Test method 43
Annex E (informative) Types of uninterruptible power systems (UPS) configurations 44

Figure 1 – Types of UPS systems 13
Figure 2 – Typical example series connected rotary UPS 13
Figure 3 – Typical example of a line interactive rotary UPS 14
Figure 4 – Parallel operation of a rotary UPS 15

Figure 5 – Bypass operation 16
Figure 6 – Illustration of rotary UPS operation 17
Figure 7 – Operating modes 18
Figure 8 – Surge test 29
Figure 9 – Warning label 34
Figure A.1 – Dual conversion – direct-coupled flywheel 37
Figure A.2 – Line interactive – direct-coupled flywheel 37
Figure A.3 – Dual conversion – indirect coupled flywheel 37
Figure A.4 – Line interactive – indirect coupled flywheel 38
Figure A.5 – Double fed a.c. machine 38
Figure A.6 – Dual conversion with battery 38
Figure A.7 – Line interactive with battery 39
Figure B.1 – Single-phase non-linear load 40
Figure C.1 – Three-phase non-linear load 42
Figure D.1 – Input mains failure test method 43
Figure E.1 – Series connected type 1 44
Figure E.2 – Series connected type 2 45
Figure E.3 – Line interactive 45
Figure E.4 – Typical UPS 46
Figure E.5 – Typical switchless dual feed UPS 47

Table 1 – Compatibility levels for individual harmonic voltages in mains power 21
Table 2 – Operating steady-state limit values for performance classes 21
Table 3 – Operating dynamic limit values for performance classes (note 1) 22
Table 4 – Technical data sheets – Manufacturers declaration 26
Table 5 – Test methods for rotary UPS performance characteristics 32